


SEATTLE CITY LIGHT
MATERIAL STANDARDS

STANDARD NUMBER: **6693.7**
PAGE: 1 of 1
DATE: December 3, 1958
Rev: April 14, 1995

**CONNECTOR - TWO-BOLT
PARALLEL CLAMP**



Two-Bolt Connectors: Connectors shall be of the configuration shown. The body and clip shall be of cast or forged bronze and bolts shall be silicon bronze. Gripping surfaces shall be serrated. A rubber or plastic retaining ring and a bronze lock washer must be fitted on each bolt to prevent loss or loosening.

Reference Specification: City Light Standard Specification No. 6600.0, latest revision.

Stock Unit: Each

Stock Number	Conductor Range		Approved Manufacturers		
	Run	Tap	Penn Union	Burndy	Dossert
669379	2/0 STR	10 STR	VT - 1	KVS26G15	DSU - 13
669380	4/0 STR	10 STR	VT - 2	KVS28G17	DSU - 21
669381	350 kcmil	10 STR	VT - 3	KVS31G14	DSU - 35
669382	500 kcmil	10 STR	VT - 4	KVS34G17	DSU - 50
669383	800 kcmil	3/0 STR	VT - 5	KVS40G10	DSU - 80
669384	1000 kcmil	3/0 STR	VT - 6	KVS44G10	DSU - 100

NOTE: Blackburn, O-Z, Bronco, Weaver, Annixter Royal, and Anderson were removed because they were either no longer manufactured or that they no longer comply with this standard due to no retaining ring and/or washers. Items returned to salvage that comply with this standard may be returned to stock.

ORIGINATOR	STANDARDS COORDINATOR	STANDARDS SUPERVISOR	UNIT DIRECTOR
<i>James L. Horn</i>	<i>Charles L. Shaffer</i>	<i>John E. Chinner</i>	<i>Dennis DeVries</i>